

PART 1: GENERAL

1.01 Purpose:

- A. This standard is intended to provide useful information to the Professional Service Provider (PSP) to establish a basis of design. The responsibility of the engineer is to apply the principles of this section such that the University may achieve a level of quality and consistency in the design and construction of their facilities. Deviations from these guidelines must be justified through LCC analysis and submitted to the University for approval.

1.02 References:

- A. Codes and Standards that are standard at the University
 - 1. Design plumbing systems in accordance with the latest version of the International Plumbing Code. Design shall conform to Uniform Plumbing Code requirements where interaction occurs with City of Huntsville utilities.

1.03 Requirements:

- A. Provide floor drains in all toilet rooms, janitor closets, and mechanical rooms.
- B. Extend cleanouts to finished floor or wall surface, with access covers installed flush to the finished surface. Ensure clearance at cleanout for rodding of drainage system.
 - 1. Residence Life Maintenance (RLM) buildings shall locate all cleanouts to exterior of building only.
 - 2. No main line cleanouts within interior of building with the exception of lavatory/kitchen sink cleanout.
- C. All interior Clean outs shall be above flood rim for inside of buildings unless prior approval by SHSU Plant Operations. Coordinate cleanout locations with Architect.
 - 1. Residence Life Maintenance buildings shall have main line sewer clean outs located every 75 feet on the exterior perimeter of the building with double cleanouts and popup plugs below flood plane.
- D. Encase exterior cleanouts in concrete with access cover installed flush with grade.
- E. Provide grease traps (interceptors) whenever there is the potential to discharge wastes containing fats, oils, greases, and/or settable solids into the sanitary sewer system.
- F. Grease traps shall have two compartments, with the primary having a seven-minute retention time and the secondary having a five-minute retention time. For cleaning and inspection purposes, traps shall be located in area accessible to appropriate grease recovery equipment. Manufactured traps that are properly sized may be used in lieu of on-site construction. When possible, the trap shall be installed outside the building. Note that all retention times shown are minimums.

- G. Buried grease traps shall be constructed of concrete.
- H. Where grease trap is located exterior to building, all pipe and fittings shall be Schedule 40 PVC. Normally traps will be installed 3-1/2" below grade, but in areas subject to vehicle traffic, shall be 8" below grade and equipped with traffic manhole frame and cover.
- I. Install RV dump type station at the inlet of grease traps to allow for trash trucks to dump liquid waste.
- J. Traps inside building shall receive cast-iron pipe and fittings.

PART 2: PRODUCTS

2.01 Above Ground Drainage and Vent Pipe And Fittings

- A. Cast-Iron Soil Pipe: ASTM A74, Service weight, hubless pipe and fittings.
 - 1. RLM – no cast iron piping SCH 40 PVC Only
- B. Heavy Duty Couplings for Hubless Cast-Iron Soil Pipe: Hubless Clamps, heavy weight, stainless steel bands. Clamps shall be constructed and tested per ASTM C-1277. For pipe sizes 1-1/2" through 4" minimum four (4) bands and for pipe sizes 5" through 15" minimum six (6) bands.
 - 1. RLM requires SCH 40 PVC
- C. Polypropylene Pipe and Fused Fittings (or Engineer-approved equal): use for acid waste and vent piping in laboratories

2.02 Underground Drain Pipe And Fittings

- A. Cast-Iron Soil Pipe: ASTM A74, Service weight, hub-and-spigot soil pipe and fittings. Pipe and fittings shall have a heavy coating of coal tar varnish or asphaltum on both inside and outside surfaces. PVC may be used but must be approved by SHSU Plant Operations.
 - 1. RLM no cast iron, requires SCH 40 PVC
- B. Neoprene Compression Gaskets: ASTM C564.
- C. Sewer Pipe and Fittings: Conform to ASTM D2729 for pipe and fittings.

2.03 Drainage Piping Specialties

- A. Expansion Joints: Cast-iron body with adjustable bronze sleeve, bronze bolts with wing nuts.
- B. Cleanout Plugs: Cast-bronze or brass, threads complying with ANSI B2.1, countersunk head.
- C. Floor Cleanouts: EXTERIOR ONLY - Cast-iron body and frame, with cleanout plug and adjustable round nickel bronze top. Do not utilize floor cleanouts on interior of buildings without prior approval from SHSU Plant Operations.
- D. Wall Cleanouts: Cast-iron body adaptable to pipe with cast-bronze or brass cleanout plug; stainless steel cover including screws.

2.04 Floor Drains

- A. Floor drains shall be provided with deep seal "P" traps at all floor drains.
- B. Floor Drain (Basement and air handler rooms) 12" x 12" floor sink with half-grate strainer, ty-seal or caulked outlet, dura-coated. Similar to Zurn Z-567. There shall be adequate floor drains to provide drain for all equipment requiring same; one per piece of equipment, to eliminate excessive drain piping across floors.
- C. Floor Drain (for boiler rooms): Cast-iron body and tractor grate, flashing flange and collar.
- D. Floor Drain (corridors): Stainless steel body with flashing collar, ty-seal or caulked outlet and adjustable strainer head, stainless steel round strainer with satin finish.
- E. Floor Drain (mechanical rooms, storage rooms and other remote areas) shall be provided with a central piped primer system which automatically primes traps building wide using a single timed valve for one minute every 24 hours (adjustable).
 - 1. RLM Requires trap guards by PROSET only

2.05 Depressed Area Drains.

- A. Floor Drain (depressed area drains): Cast-iron body for horizontal mounting secured grate.
- B. Floor Drain (medium to heavy traffic and drainage): Cast-iron body and flashing collar with adjustable top and tractor grate.
- C. Floor Drain (shower and toilet rooms): Cast-iron body and flashing collar with the following features; square nickel bronze adjustable strainer head with secured square hole grate.

2.06 Trench Drains

- A. Cast-iron shallow hub body and grate with end plates and gaskets, assembled in standard lengths for total length and width as required for application.
- B. Non-Metallic Trench Drains shall be polyester resin and quartz aggregate, precast, interlocking design, with bottom radius and 0.6 percent slope
- C. Precast Material: Load pressure of 14,500 psi, bending pressure of 2,900 psi, frost-proof, salt-proof, inert under dilute acid and alkali conditions, and less than 1.0 percent water absorption rate
- D. Grates: Cast iron or steel as indicated, for heavy-duty truck traffic, with openings designed to prevent entry of bicycle or wheelchair tires

2.07 Roof Drains

- A. Roof Drain (General Purpose): Cast-iron body with combined flashing collar and gravel stop, cast-iron dome.
- B. Roof Drain (controlled flow): Cast-iron body, combined flashing collar and gravel stop, cast-iron dome with adjustable flow rate control assembly
- C. Roof Drain (parapet roofs): Cast-iron body, flashing device, loose set grate.

2.08 Grease Traps

- A. Size traps according to the following criteria:

Kind of Fixture	Trap and Trap Arm Size	Fixture Unit
3 compartment sink	1-1/2", 2"	3, 4
2 compartment sink	1-1/2"	2
Dishwasher	2"	4
Garbage Grinder	2"	4
Wok Stove	2"	4
Floor Drains (2", 3", 4")	2", 3", 4"	2, 3, 4 (1/2 credit)
Floor sinks (3", 4")	3", 4"	3, 4
Hand Sink		0*
Mop Sink		0*

*Notes: Hand sinks and mop sinks are not required to be plumbed to the Grease Trap. For indirect waste to Floor Sinks and Hub Drains used as receptors for dishwashers, 2 and 3 compartment sinks, etc., the fixture unit count shall be two times (2x) the floor sink fixture count. Fixtures receiving non-grease bearing wastes may be drained through a trap, but shall not be included for the trap sizing.

- B. Trap liquid holding capacity (gallons) = Total Fixture Count X Applicable retention time (minutes) X 3, as per Industrial Waste Department requirements.

PART 3: EXECUTION

3.01 Pipe Applications - Above Ground, Within Building

- A. Install hubless, service weight, cast-iron soil pipe and fittings for drainage and vent pipe.
1. RLM no Cast iron SCH 40 PVC ONLY

3.02 Pipe Applications - Below Ground, Within Building

- A. Install hub-and-spigot, extra-heavy weight, cast-iron, soil pipe and fittings with gasketed joints for 15 inch and smaller drainage pipe. PVC may be used with prior approval from SHSU Plant Operations

1. RLM no Cast iron SCH 40 PVC ONLY

3.03 Installation

ll branch connections.

B. Route exposed piping at right angles or parallel to building walls. Diagonal runs are not permitted, unless expressly indicated.

D. Conceal all pipe installations in walls, pipe chases, utility spaces, above ceilings, below grade or floors, unless indicated to be exposed to view.

E. Route piping tight to slabs, beams, joists, columns, walls, and other permanent elements of the building. Allow sufficient space above removable ceiling panels to remove panel.

F. Exterior Wall Penetrations: Seal pipe penetrations through exterior walls using sleeves and mechanical sleeve seals. Pipe sleeves smaller than 6 inch shall be steel; pipe sleeves 6 inch and larger shall be sheet metal.

H. Fire Barrier Penetrations: Provide where pipes pass through fire rated walls, partitions, ceilings, and floors, maintain the fire rated integrity.

I. Make changes in direction for drainage and vent piping using appropriate 45 degree wyes, half-wyes, or long sweep quarter, sixth, eighth, or sixteenth bends. Sanitary tees or short quarter bends may be used on vertical stacks of drainage lines where the change in direction of flow is from horizontal to vertical, except use long-turn tees where two fixtures are installed back to back and have a common drain. Straight tees, elbows, and crosses may be used on vent lines. No change in direction of flow greater than 90 degrees shall be made. Where different sizes of drainage pipes and fittings are connected, use proper size, standard increasers and reducers. Reduction of the size of drainage piping in the direction of flow is prohibited.

J. Install underground building drains in accordance with the Cast Iron Soil Pipe Institute Engineering Manual. Provide underground building drains beginning at low point of systems, true to grades and alignment indicated with unbroken continuity of invert. Provide bell ends of piping facing upstream. Provide required gaskets in accordance with manufacturer's recommendations for use of lubricants, cements, and other special installation requirements.

1. RLM no Cast iron SCH 40 PVC ONLY

K. Provide building drain piping pitched per code requirements.

M. Provide sleeve and mechanical sleeve seal through foundation wall for watertight installation.

N. Provide 1-inch thick extruded polystyrene over underground building drain piping not under building. Width of insulation shall extend a minimum of 12 inches beyond each side of pipe.

3.08 Installation Of Piping Specialties

A. Do not install backwater valves in sanitary building drain piping.

B. Install expansion joints on vertical risers as indicated, and as required by the plumbing code.

C. Above Ground Cleanouts: Install in above ground piping and building drain piping as indicated, and:

1. as required by plumbing code;

2. at each change in direction of piping greater than 45 degrees;

3. at minimum intervals of 50' and maximum of 80' for piping 4" and smaller and 75' for larger piping.

4. RLM Requires double cleanout with pop-up cleanout plugs outside perimeter of building every 75ft.

4. at the base of each vertical soil or waste stack.

3.9 Installation Of Floor Drains

A. Set drain grate depressed below finished slab elevation as listed below:

DEPRESSION IN INCHES RADIUS OF AREA DRAINED - FEET

1/2	5
3/4	10
1	15
1-1/4	20
1-1/2	25

END OF STANDARD